



Ref : CWWDA/MSA/004/2024-2025/008

Date : 5<sup>th</sup> March 2025

To all Bidders

**RE: WATER SUPPLY TO THE CREEK VILLAGE AFFORDABLE HOUSING UNITS IN KISAUNI CONSTITUENCY, MOMBASA COUNTY (CONTRACT NO. CWWDA/T/MSA/W/004/2024-2025)**

**Clarification No.1**

The above subject matter refers.

Please find our response to your request for clarification regarding the above-mentioned tender. Tender clarification No. 1 has been uploaded on our website, <https://www.cwwda.go.ke/tenders>.

The other terms and conditions of the bid remain the same.

Yours faithfully,

**Eng. Martin Tsuma**  
**Ag. CHIEF EXECUTIVE OFFICER**



**CLARIFICATION NO.1**

<b>BILL NO</b>	<b>QUESTION / REQUEST FOR CLARIFICATION</b>	<b>RESPONSE</b>
Bill no. 2: Transmission pipeline.	<b>Item 1.4 specifies excavation in rock depths not exceeding 1000.</b> Please confirm that this will be applicable to pipeline excavation as EXTRA OVER ITEM for excavations in trenches for pipelines for bill 2 item 2.21, 2.22, 2.23 and 3.1	<b>Yes</b> , this will apply to trenching and Pipe laying as extra over for items <b>2.25, 2.26, 2.27, and 2.28</b> as clarified in <b>Addendum No.1 Bills of Quantities</b>
Bill 2: item 3.1	Please confirm / clarify that the <b>PREAMBLE HEADING as described in item 2.2 PIPEWORK AND FITTINGS</b> on supply, transport, laying, excavation etc. applies also to item 3.1	<b>Yes</b> , this item includes Supply and Transport to site. Transport from site store, lay and joint pipes in trench, include for excavation, preparation of surfaces, disposal of excavate material, shoring sides of excavation and backfilling as clarified in <b>Addendum No.1 Bills of Quantities</b>
Bill no 4: RC RETAINING WALL	Please issue the layout drawing of the retaining wall	The Reinforced Concrete (RC) retaining wall (approx. 100m long) is to protect the wastewater treatment plant and the 500m <sup>3</sup> rc water Tank at sea front slope section. Additionally, you are welcome to visit the site for further assessment and clarification.
Bill no 4: Retaining wall item 4.23 -FILL MATERIAL	Please clarify the source of the fill materials under item 4.23. is it available at site? if not, how far is the burrow pit?	The material is available on site

**MANDATORY REQUIREMENTS**

<b>QUESTION / REQUEST FOR CLARIFICATION</b>	<b>QUALIFICATION REQUIREMENTS</b>	<b>RESPONSE</b>	
		<b>INSTRUCTIONS</b>	<b>DOCUMENTS TO BE PROVIDED</b>
<b>Page 22,Raw-10:</b> In the Tender Document section III evaluation and qualification criteria under mandatories, there is a requirement that states as follows;  "NCA 5 and above for Water Works	Registration with NCA 5 and above	Attach copy of Certificate of Registration and License	Certificate of Registration and License
	Class 4 and above or Equivalent licensed Water Supply & Sewerage Contractor Registered with Ministry of Water, Sanitation and Irrigation.	Attach copy of Certificate of Registration and License	Certificate of Registration and License

<p>Class 4 and above or Equivalent licensed Water Supply &amp; Sewerage Contractor Registered with Ministry of Water, Sanitation and Irrigation"</p> <p>From the above requirement, are we supposed to provide NCA 5 water works license or Water Contractor license from ministry of water and irrigation or are supposed to provide both? Can either do? For example, if we only have NCA Water Certificate and license is it sufficient for this specific requirement?</p> <p>Kindly Clarify this to enable us complete the bid compilation.</p>	<p>Financial Alterations</p>	<p>If Any must be countersigned by the bidder</p>	<p>Ccountersigned by the bidder</p>
---	------------------------------	---	-------------------------------------