

COAST WATER WORKS DEVELOPMENT AGENCY



**TENDER FOR DESIGN/BUILDING OF MAKAMINI DAM
RESPONSE TO CLARIFICATION No. 3**

No	Reference	Query	Reply
1	Volume 1 of 3 Bidding Procedures Page 86 Form of Bid security The beneficiary is not designated.	Please provide detailed information about beneficiary including name and address.	Coast Water Works Development Agency, Mikindani Street, Off-Nkrumah Road, P.O. Box 90417-80100 Mombasa, Kenya. Tel: (041) 2315230 Email: info@cwvda.go.ke
2	Volume 1 of 3 Bidding Procedures Page 86 Form of Bid security This guarantee is subject to the Uniform Rules for Demand Guarantees, ICC Publication No.458.	Please clarify whether we can replace it with “This guarantee is subject to the Uniform Rules for Demand Guarantees, ICC Publication No.758”.	Replace ‘No. 458’ with ‘No. 758’ as it the latest edition.
3	As NCA's new regulations states that foreign contractors cannot apply for NCA Certificate	could we provide it later for this particular project	No, comply with NCA regulations
4	Bids shall be valid for 120 days after submission date	Clarify if its 120 or 119 days	Valid until and including 12th September, 2020 after submission on 15th May 2020
5	Provide Specific Experience for contracts completed and under implementation as prime contractor	Clarify whether this means contracts completed and ongoing	Yes

No	Reference	Query	Reply
		projects	
6	Since we are foreign contractors, it is hard for us provide many EBK certificates	Can we provide foreign certificates which are equivalent to EBK	Yes with English translation of the certificates
7	According to Section III of the Evaluation and Qualification Criteria, Clause No.4.1 (a) and 4.2 (a) as attached herein, it's stated that the bidders should provide Design and Construction Experience	Clarify whether we should provide Design and Construction Experience Independently.	Refer to Sect. III (Qualification): Clause 4.1&4.2
8	The invitation for Tender indicates the capacity of Clear Water Tank to be 1,000m ³ . Under Price Schedule No.10, a second Clear Water Tank has been included (5,000m ³).	Clarify how many Clear Water Tanks are required and for what capacity	Three (3) clear water tanks of 1,000 m³ capacity each with a total combined storage capacity of 3,000 m³
9	Price Schedule 9, item 9.7 provides for pricing of a Back-wash Water Tank	Price Schedule No.11 provides for an elevated water tank (200m ³). This is a duplication of the same Item. Kindly Clarify.	The Back washing tank is one (1) elevated tank with a capacity of 200 m³
10	The Bidder is required to provide a Bid Design that meets the Employer's requirements. At this stage it is practically not possible to provide Detailed Designs. A provision has been made in the Price Schedules for Detailed Designs upon successful award of the Project.	If the Bidder reviews the Designs (egis,2019) and finds them acceptable with minor modifications, Is it acceptable to adopt these Designs and present them under the Bid Design for the Dam for the Technical Evaluation	No. You may cost/or price your bid based on this preliminary design and in case you win the tender you will provide the detailed design based on this preliminary design.

No	Reference	Query	Reply
		purposes?	
11	In reference to the price schedules provided, bill no.: 2.2. Provisional sums and price schedules-Appendix III: Operation and maintenance cost	Clarify more what Item III refers to since the sections mentioned above have two conflicting/contradictory meanings?	This is a breakdown of the costs to help to build up the costs as well as specifying the main cost items of operation and maintenance.

Please note that other conditions of the bidding Process remain the same.

Chief Executive Officer
Coast Water Works Development Agency,
Mikindani Street, Off-Nkrumah Road,
Mombasa, Kenya.
Tel: (041) 2315230
Email: info@cwvda.go.ke